



3 Garden Street  
Morwell Vic 3840  
[australiansolidfueltesting@gmail.com](mailto:australiansolidfueltesting@gmail.com)  
NATA Accreditation No. 20042

03 August 2022

Mr Ashley Stride  
Jetmaster (Vic)  
444 Swan Street  
RICHMOND VIC 3121

To Whom it May Concern,

**RE: BAL Rating for VisionLINE Safety Vent Air Flue Kit**

The VisionLINE Safety Vent Air Flue Kit has been tested to and passed both Appendix B and Appendix F of AS/NZS2918;2018. During this testing the flue kit is exposed to temperatures of greater than 1100°C for periods longer than 2hrs with no adverse effect on the integrity of the flue kit.

The VisionLINE Safety Vent Air Flue Kit is a fully sealed flue kit with the venting at the cowl only feeding air to the combustion air inlet of the heating appliance and is a fully sealed system. Therefore, there is no opening for bushfire sparks or embers to enter the dwelling via the cowl or outer casing as per a standard flue system. The flue kit is also constructed entirely of non-combustible materials.

It is in our opinion that the VisionLINE Safety Vent Air Flue Kit meets the requirements of BAL-40 and BAL-FZ building requirements.

Warm regards,

A handwritten signature in blue ink, appearing to read 'Steve Marland', is written over a light blue circular stamp.

Steve Marland  
Managing Director

Australian Solid Fuel Testing

